

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 16)**

Water Level of the accumulated water (at 7:00 on July 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,278 mm (43 mm decrease since 16:00 on July 15)	O.P.+ 2,890 mm (20 mm increase since 16:00 on July 15)	—
	Water level of Turbine Building	O.P.+ 2,937 mm (5 mm increase since 16:00 on July 15)	O.P.+ 3,188 mm (38 mm decrease since 16:00 on July 15)	O.P.+ 2,756 mm (35 mm increase since 16:00 on July 15)	O.P.+ 2,744 mm (3 mm increase since 16:00 on July 15)
	Water level of Reactor Building	O.P.+ 4,623 mm (27 mm increase since 16:00 on July 15)	O.P.+ 3,512 mm (34 mm decrease since 16:00 on July 15)	O.P.+ 2,985 mm (39 mm increase since 16:00 on July 15)	O.P.+ 2,763 mm (8 mm decrease since 16:00 on July 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,380 mm (Increase from initial level:4,597 mm, 117 mm decrease since 16:00 on July 15) O.P.+ 2,002 mm (Increase from initial level:2,728 mm, 167 mm increase since 16:00 on July 15) O.P.+ 4,382 mm (Water level from floor:586 mm, 1 mm increase since 16:00 on July 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 11:20 on July 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:53 on July 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:30 on June 27 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:11 on July 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.