

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 17)**

Water Level of the accumulated water (at 7:00 on July 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,218 mm (36 mm decrease since 16:00 on July 16)	O.P.+ 2,920 mm (17 mm increase since 16:00 on July 16)	—
	Water level of Turbine Building	O.P.+ 2,946 mm (5 mm increase since 16:00 on July 16)	O.P.+ 3,136 mm (31 mm decrease since 16:00 on July 16)	O.P.+ 2,792 mm (21 mm increase since 16:00 on July 16)	O.P.+ 2,762 mm (12 mm increase since 16:00 on July 16)
	Water level of Reactor Building	O.P.+ 4,621 mm (7 mm decrease since 16:00 on July 16)	O.P.+ 3,462 mm (31 mm decrease since 16:00 on July 16)	O.P.+ 3,025 mm (23 mm increase since 16:00 on July 16)	O.P.+ 2,769 mm (6 mm increase since 16:00 on July 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,234 mm (Increase from initial level:4,451 mm, 90 mm decrease since 16:00 on July 16) O.P.+ 2,269 mm (Increase from initial level:2,995 mm, 166 mm increase since 16:00 on July 16) O.P.+ 4,383 mm (Water level from floor:587 mm, 1 mm increase since 16:00 on July 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 11:20 on July 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:53 on July 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:30 on June 27 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:53 on July 17 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:53 AM on July 17, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.