

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 19)**

Water Level of the accumulated water (at 7:00 on July 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,117 mm (28 mm decrease since 16:00 on July 18)	O.P.+ 2,949 mm (10 mm increase since 16:00 on July 18)	—
	Water level of Turbine Building	O.P.+ 2,969 mm (8 mm increase since 16:00 on July 18)	O.P.+ 3,051 mm (24 mm decrease since 16:00 on July 18)	O.P.+ 2,819 mm (11 mm increase since 16:00 on July 18)	O.P.+ 2,801 mm (11 mm increase since 16:00 on July 18)
	Water level of Reactor Building	O.P.+ 4,656 mm (4 mm increase since 16:00 on July 18)	O.P.+ 3,381 mm (30 mm decrease since 16:00 on July 18)	O.P.+ 3,058 mm (6 mm increase since 16:00 on July 18)	O.P.+ 2,806 mm (10 mm increase since 16:00 on July 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,230 mm (Increase from initial level:4,447 mm, 5 mm increase since 7:00 on July 18) O.P.+ 2,440 mm (Increase from initial level:3,166 mm, 40 mm increase since 7:00 on July 18) O.P.+ 4,384 mm (Water level from floor:588 mm, No change since 7:00 on July 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 11:20 on July 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:07 on July 17)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:37 on July 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.