

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 19)**

Water Level of the accumulated water (at 16:00 on July 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,098 mm (19 mm decrease since 7:00 on July 19)	O.P.+ 2,953 mm (4 mm increase since 7:00 on July 19)	—
	Water level of Turbine Building	O.P.+ 2,973 mm (4 mm increase since 7:00 on July 19)	O.P.+ 3,035 mm (16 mm decrease since 7:00 on July 19)	O.P.+ 2,823 mm (4 mm increase since 7:00 on July 19)	O.P.+ 2,806 mm (5 mm increase since 7:00 on July 19)
	Water level of Reactor Building	O.P.+ 4,647 mm (9 mm decrease since 7:00 on July 19)	O.P.+ 3,362 mm (19 mm decrease since 7:00 on July 19)	O.P.+ 3,064 mm (6 mm increase since 7:00 on July 19)	O.P.+ 2,810 mm (4 mm increase since 7:00 on July 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,233 mm (Increase from initial level:4,450 mm, 8 mm increase since 7:00 on July 19) O.P.+ 2,461 mm (Increase from initial level:3,187 mm, 61 mm increase since 7:00 on July 19) O.P.+ 4,385 mm (Water level from floor:589 mm, 1 mm increase since 7:00 on July 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 11:20 on July 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:07 on July 17)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:37 on July 17   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.