

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 22)**

Water Level of the accumulated water (at 7:00 on July 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,986 mm (25 mm decrease since 16:00 on July 21)	O.P.+ 2,982 mm (8 mm increase since 16:00 on July 21)	—
	Water level of Turbine Building	O.P.+ 2,904 mm (3 mm increase since 16:00 on July 21)	O.P.+ 2,940 mm (20 mm decrease since 16:00 on July 21)	O.P.+ 2,855 mm (11 mm increase since 16:00 on July 21)	O.P.+ 2,837 mm (7 mm increase since 16:00 on July 21)
	Water level of Reactor Building	O.P.+ 4,457 mm (45 mm decrease since 16:00 on July 21)	O.P.+ 3,265 mm (21 mm decrease since 16:00 on July 21)	O.P.+ 3,093 mm (7 mm increase since 16:00 on July 21)	O.P.+ 2,840 mm (6 mm increase since 16:00 on July 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,297 mm (Increase from initial level:4,514 mm, 3 mm increase since 16:00 on July 21) O.P.+ 2,591 mm (Increase from initial level:3,317 mm, 34 mm increase since 16:00 on July 21) O.P.+ 4,231 mm (Water level from floor:435 mm, 1 mm increase since 16:00 on July 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 11:20 on July 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:07 on July 17)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:30 on July 22 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 7:30 AM on July 22, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.