

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 23)**

Water Level of the accumulated water (at 7:00 on July 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,073 mm (61 mm increase since 16:00 on July 22)	O.P.+ 3,004 mm (16 mm increase since 16:00 on July 22)	—
	Water level of Turbine Building	O.P.+ 2,918 mm (9 mm increase since 16:00 on July 22)	O.P.+ 3,012 mm (51 mm increase since 16:00 on July 22)	O.P.+ 2,878 mm (17 mm increase since 16:00 on July 22)	O.P.+ 2,853 mm (12 mm increase since 16:00 on July 22)
	Water level of Reactor Building	O.P.+ 4,454 mm (21 mm increase since 16:00 on July 22)	O.P.+ 3,325 mm (57 mm increase since 16:00 on July 22)	O.P.+ 3,121 mm (19 mm increase since 16:00 on July 22)	O.P.+ 2,855 mm (10 mm increase since 16:00 on July 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,304 mm (Increase from initial level:4,521 mm, 4 mm increase since 16:00 on July 22) O.P.+ 2,443 mm (Increase from initial level:3,169 mm, 295 mm decrease since 16:00 on July 22) O.P.+ 4,232 mm (Water level from floor:436 mm, No change since 16:00 on July 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:51 on July 22 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.