

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 23)**

Water Level of the accumulated water (at 16:00 on July 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,107 mm (34 mm increase since 7:00 on July 23)	O.P.+ 3,011 mm (7 mm increase since 7:00 on July 23)	—
	Water level of Turbine Building	O.P.+ 2,923 mm (5 mm increase since 7:00 on July 23)	O.P.+ 3,043 mm (31 mm increase since 7:00 on July 23)	O.P.+ 2,889 mm (11 mm increase since 7:00 on July 23)	O.P.+ 2,861 mm (8 mm increase since 7:00 on July 23)
	Water level of Reactor Building	O.P.+ 4,461 mm (7 mm increase since 7:00 on July 23)	O.P.+ 3,349 mm (24 mm increase since 7:00 on July 23)	O.P.+ 3,128 mm (7 mm increase since 7:00 on July 23)	O.P.+ 2,863 mm (8 mm increase since 7:00 on July 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,305 mm (Increase from initial level:4,522 mm, 1 mm increase since 7:00 on July 23) O.P.+ 2,251 mm (Increase from initial level:2,977 mm, 192 mm decrease since 7:00 on July 23) O.P.+ 4,233 mm (Water level from floor:437 mm, 1 mm increase since 7:00 on July 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:51 on July 22 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.