

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 25)**

Water Level of the accumulated water (at 7:00 on July 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,239 mm (48 mm increase since 16:00 on July 24)	O.P.+ 3,036 mm (8 mm increase since 16:00 on July 24)	—
	Water level of Turbine Building	O.P.+ 2,994 mm (8 mm increase since 16:00 on July 24)	O.P.+ 3,204 mm (40 mm increase since 16:00 on July 24)	O.P.+ 2,965 mm (10 mm increase since 16:00 on July 24)	O.P.+ 2,887 mm (11 mm increase since 16:00 on July 24)
	Water level of Reactor Building	O.P.+ 3,985 mm (11 mm increase since 16:00 on July 24)	O.P.+ 3,264 mm (43 mm increase since 16:00 on July 24)	O.P.+ 3,006 mm (11 mm increase since 16:00 on July 24)	O.P.+ 2,888 mm (10 mm increase since 16:00 on July 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,517 mm (Increase from initial level:3,734 mm, 4 mm increase since 16:00 on July 24) O.P.+ 1,344 mm (Increase from initial level:2,070 mm, 325 mm decrease since 16:00 on July 24) O.P.+ 4,233 mm (Water level from floor:437 mm, No change since 16:00 on July 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:51 on July 22 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.