## Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 25)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on July 25)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,258 mm (19 mm increase since 7:00 on July 25)	O.P.+ 3,043 mm (7 mm increase since 7:00 on July 25)	_
	Water level of Turbine Building	O.P.+ 2,995 mm (1 mm increase since 7:00 on July 25)	O.P.+ 3,220 mm (16 mm increase since 7:00 on July 25)	O.P.+ 2,966 mm (1 mm increase since 7:00 on July 25)	O.P.+ 2,893 mm (6 mm increase since 7:00 on July 25)
	Water level of Reactor Building	O.P.+ 3,993 mm (8 mm increase since 7:00 on July 25)	O.P.+ 3,282 mm (18 mm increase since 7:00 on July 25)	O.P.+ 3,014 mm (8 mm increase since 7:00 on July 25)	O.P.+ 2,894 mm (6 mm increase since 7:00 on July 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building	O.P.+ 2,520 mm (Increase from initial level:3,737 mm, 3 mm increase since 7:00 on July 25)		
		High Temperature Incinerator Building	O.P.+ 1,196 mm (Increase from initial level:1,922 mm, 148 mm decrease since 7:00 on July 25)		
		On-site Bunker Building	O.P.+ 4,234 mm (Water level from floor:438 mm, 1 mm increase since 7:00 on July 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		_	_	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:18 on July 25)	_
		Unit 5 and 6			
		_			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:51 on July 22 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

% For quick publication of the data of water level, values are provided as reference values.