

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 26)**

Water Level of the accumulated water (at 16:00 on July 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,296 mm (7 mm decrease since 7:00 on July 26)	O.P.+ 3,021 mm (1 mm increase since 7:00 on July 26)	—
	Water level of Turbine Building	O.P.+ 3,014 mm (6 mm increase since 7:00 on July 26)	O.P.+ 3,255 mm (5 mm decrease since 7:00 on July 26)	O.P.+ 2,928 mm (14 mm increase since 7:00 on July 26)	O.P.+ 2,888 mm (3 mm decrease since 7:00 on July 26)
	Water level of Reactor Building	O.P.+ 4,053 mm (44 mm increase since 7:00 on July 26)	O.P.+ 3,334 mm (15 mm increase since 7:00 on July 26)	O.P.+ 2,973 mm (6 mm increase since 7:00 on July 26)	O.P.+ 2,898 mm (3 mm increase since 7:00 on July 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,525 mm (Increase from initial level:3,742 mm, 2 mm increase since 7:00 on July 26) O.P.+ 1,339 mm (Increase from initial level:2,065 mm, 56 mm increase since 7:00 on July 26) O.P.+ 4,235 mm (Water level from floor:439 mm, 1 mm increase since 7:00 on July 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:33 on July 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:18 on July 25)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:51 on July 22   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.