

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 29)**

Water Level of the accumulated water (at 7:00 on July 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,147 mm (34 mm decrease since 16:00 on July 28)	O.P.+ 3,079 mm (9 mm increase since 16:00 on July 28)	—
	Water level of Turbine Building	O.P.+ 3,060 mm (9 mm increase since 16:00 on July 28)	O.P.+ 3,128 mm (27 mm decrease since 16:00 on July 28)	O.P.+ 2,998 mm (7 mm increase since 16:00 on July 28)	O.P.+ 2,928 mm (11 mm increase since 16:00 on July 28)
	Water level of Reactor Building	O.P.+ 4,213 mm (13 mm increase since 16:00 on July 28)	O.P.+ 3,206 mm (28 mm decrease since 16:00 on July 28)	O.P.+ 3,045 mm (5 mm increase since 16:00 on July 28)	O.P.+ 2,928 mm (9 mm increase since 16:00 on July 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,539 mm (Increase from initial level:3,756 mm, 4 mm increase since 16:00 on July 28) O.P.+ 1,668 mm (Increase from initial level:2,394 mm, 77 mm increase since 16:00 on July 28) O.P.+ 4,237 mm (Water level from floor:441 mm, 1 mm increase since 16:00 on July 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:33 on July 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:18 on July 25)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:51 on July 22 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.