

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 30)**

Water Level of the accumulated water (at 7:00 on July 30)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,100 mm (28 mm decrease since 16:00 on July 29)	O.P.+ 3,099 mm (13 mm increase since 16:00 on July 29)	—
	Water level of Turbine Building	O.P.+ 3,082 mm (14 mm increase since 16:00 on July 29)	O.P.+ 3,087 mm (26 mm decrease since 16:00 on July 29)	O.P.+ 3,021 mm (15 mm increase since 16:00 on July 29)	O.P.+ 2,946 mm (12 mm increase since 16:00 on July 29)
	Water level of Reactor Building	O.P.+ 4,225 mm (18 mm increase since 16:00 on July 29)	O.P.+ 3,172 mm (20 mm decrease since 16:00 on July 29)	O.P.+ 3,071 mm (19 mm increase since 16:00 on July 29)	O.P.+ 2,946 mm (13 mm increase since 16:00 on July 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,545 mm (Increase from initial level:3,762 mm, 3 mm increase since 16:00 on July 29) O.P.+ 1,789 mm (Increase from initial level:2,515 mm, 76 mm increase since 16:00 on July 29) O.P.+ 4,238 mm (Water level from floor:442 mm, No change since 16:00 on July 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:33 on July 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:18 on July 25)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:51 on July 22   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.