

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 1)**

Water Level of the accumulated water (at 7:00 on August 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,007 mm (29 mm decrease since 16:00 on July 31)	O.P.+ 3,129 mm (7 mm increase since 16:00 on July 31)	—
	Water level of Turbine Building	O.P.+ 3,123 mm (12 mm increase since 16:00 on July 31)	O.P.+ 3,009 mm (26 mm decrease since 16:00 on July 31)	O.P.+ 3,051 mm (8 mm increase since 16:00 on July 31)	O.P.+ 2,979 mm (11 mm increase since 16:00 on July 31)
	Water level of Reactor Building	O.P.+ 4,181 mm (10 mm decrease since 16:00 on July 31)	O.P.+ 3,094 mm (20 mm decrease since 16:00 on July 31)	O.P.+ 3,105 mm (11 mm increase since 16:00 on July 31)	O.P.+ 2,978 mm (12 mm increase since 16:00 on July 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,812 mm (Increase from initial level:4,029 mm, 236 mm increase since 16:00 on July 31) O.P.+ 2,504 mm (Increase from initial level:3,230 mm, 39 mm increase since 16:00 on July 31) O.P.+ 4,240 mm (Water level from floor:444 mm, No change since 16:00 on July 31)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:33 on July 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 14:00 on July 31)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 21:53 on July 30   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.