

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 5)**

Water Level of the accumulated water (at 7:00 on August 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,375 mm (51 mm increase since 16:00 on August 4)	O.P.+ 3,024 mm (18 mm decrease since 16:00 on August 4)	—
	Water level of Turbine Building	O.P.+ 2,758 mm (15 mm increase since 16:00 on August 4)	O.P.+ 3,323 mm (43 mm increase since 16:00 on August 4)	O.P.+ 2,865 mm (22 mm decrease since 16:00 on August 4)	O.P.+ 2,890 mm (20 mm decrease since 16:00 on August 4)
	Water level of Reactor Building	O.P.+ 4,224 mm (4 mm increase since 16:00 on August 4)	O.P.+ 3,372 mm (43 mm increase since 16:00 on August 4)	O.P.+ 2,911 mm (23 mm decrease since 16:00 on August 4)	O.P.+ 2,913 mm (12 mm decrease since 16:00 on August 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,299 mm (Increase from initial level:4,516 mm, 4 mm increase since 16:00 on August 4) O.P.+ 1,772 mm (Increase from initial level:2,498 mm, 15 mm decrease since 16:00 on August 4) O.P.+ 4,244 mm (Water level from floor:448 mm, 1 mm increase since 16:00 on August 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:25 on August 1   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.