

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 6)**

Water Level of the accumulated water (at 7:00 on August 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,326 mm (40 mm decrease since 16:00 on August 5)	O.P.+ 3,021 mm (5 mm increase since 16:00 on August 5)	—
	Water level of Turbine Building	O.P.+ 2,778 mm (13 mm increase since 16:00 on August 5)	O.P.+ 3,282 mm (34 mm decrease since 16:00 on August 5)	O.P.+ 2,925 mm (41 mm increase since 16:00 on August 5)	O.P.+ 2,873 mm (7 mm decrease since 16:00 on August 5)
	Water level of Reactor Building	O.P.+ 4,252 mm (25 mm increase since 16:00 on August 5)	O.P.+ 3,361 mm (23 mm decrease since 16:00 on August 5)	O.P.+ 2,970 mm (50 mm increase since 16:00 on August 5)	O.P.+ 2,898 mm (6 mm decrease since 16:00 on August 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,308 mm (Increase from initial level:4,525 mm, 5 mm increase since 16:00 on August 5) O.P.+ 1,764 mm (Increase from initial level:2,490 mm, 3 mm decrease since 16:00 on August 5) O.P.+ 4,245 mm (Water level from floor:449 mm, 1 mm increase since 16:00 on August 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:06 on August 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:22 on August 6 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 8:22 AM on August 6, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.