

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 6)**

Water Level of the accumulated water (at 16:00 on August 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,306 mm (20 mm decrease since 7:00 on August 6)	O.P.+ 3,029 mm (8 mm increase since 7:00 on August 6)	—
	Water level of Turbine Building	O.P.+ 2,787 mm (9 mm increase since 7:00 on August 6)	O.P.+ 3,264 mm (18 mm decrease since 7:00 on August 6)	O.P.+ 2,936 mm (11 mm increase since 7:00 on August 6)	O.P.+ 2,877 mm (4 mm increase since 7:00 on August 6)
	Water level of Reactor Building	O.P.+ 4,263 mm (11 mm increase since 7:00 on August 6)	O.P.+ 3,342 mm (19 mm decrease since 7:00 on August 6)	O.P.+ 2,981 mm (11 mm increase since 7:00 on August 6)	O.P.+ 2,894 mm (4 mm decrease since 7:00 on August 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,310 mm (Increase from initial level:4,527 mm, 2 mm increase since 7:00 on August 6) O.P.+ 1,901 mm (Increase from initial level:2,627 mm, 137 mm increase since 7:00 on August 6) O.P.+ 4,245 mm (Water level from floor:449 mm, No change since 7:00 on August 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:06 on August 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:43 on August 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	– At 8:22 AM on August 6, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 11:21 AM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 11:43 AM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.