

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 7)**

Water Level of the accumulated water (at 7:00 on August 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,272 mm (34 mm decrease since 16:00 on August 6)	O.P.+ 3,042 mm (13 mm increase since 16:00 on August 6)	—
	Water level of Turbine Building	O.P.+ 2,802 mm (15 mm increase since 16:00 on August 6)	O.P.+ 3,235 mm (29 mm decrease since 16:00 on August 6)	O.P.+ 2,952 mm (16 mm increase since 16:00 on August 6)	O.P.+ 2,887 mm (10 mm increase since 16:00 on August 6)
	Water level of Reactor Building	O.P.+ 4,281 mm (18 mm increase since 16:00 on August 6)	O.P.+ 3,313 mm (29 mm decrease since 16:00 on August 6)	O.P.+ 2,997 mm (16 mm increase since 16:00 on August 6)	O.P.+ 2,895 mm (1 mm increase since 16:00 on August 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,315 mm (Increase from initial level:4,532 mm, 5 mm increase since 16:00 on August 6) O.P.+ 1,936 mm (Increase from initial level:2,662 mm, 35 mm increase since 16:00 on August 6) O.P.+ 4,245 mm (Water level from floor:449 mm, No change since 16:00 on August 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:06 on August 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:43 on August 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.