

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 12)**

Water Level of the accumulated water (at 7:00 on August 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,027 mm (31 mm decrease since 16:00 on August 11)	O.P.+ 3,116 mm (7 mm increase since 16:00 on August 11)	—
	Water level of Turbine Building	O.P.+ 2,902 mm (11 mm increase since 16:00 on August 11)	O.P.+ 3,026 mm (27 mm decrease since 16:00 on August 11)	O.P.+ 3,027 mm (9 mm increase since 16:00 on August 11)	O.P.+ 2,958 mm (9 mm increase since 16:00 on August 11)
	Water level of Reactor Building	O.P.+ 4,097 mm (30 mm decrease since 16:00 on August 11)	O.P.+ 3,108 mm (25 mm decrease since 16:00 on August 11)	O.P.+ 3,078 mm (10 mm increase since 16:00 on August 11)	O.P.+ 2,955 mm (6 mm increase since 16:00 on August 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,355 mm (Increase from initial level:4,572 mm, 11 mm decrease since 16:00 on August 11) O.P.+ 2,220 mm (Increase from initial level:2,946 mm, 37 mm increase since 16:00 on August 11) O.P.+ 4,250 mm (Water level from floor:454 mm, No change since 16:00 on August 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:06 on August 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:21 on August 12 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 8:21 AM on August 12, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.