

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 12)**

Water Level of the accumulated water (at 16:00 on August 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,051 mm (24 mm increase since 7:00 on August 12)	O.P.+ 3,107 mm (9 mm decrease since 7:00 on August 12)	—
	Water level of Turbine Building	O.P.+ 2,909 mm (7 mm increase since 7:00 on August 12)	O.P.+ 3,046 mm (20 mm increase since 7:00 on August 12)	O.P.+ 3,003 mm (24 mm decrease since 7:00 on August 12)	O.P.+ 2,960 mm (2 mm increase since 7:00 on August 12)
	Water level of Reactor Building	O.P.+ 4,082 mm (15 mm decrease since 7:00 on August 12)	O.P.+ 3,107 mm (1 mm decrease since 7:00 on August 12)	O.P.+ 3,063 mm (15 mm decrease since 7:00 on August 12)	O.P.+ 2,959 mm (4 mm increase since 7:00 on August 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,358 mm (Increase from initial level:4,575 mm, 3 mm increase since 7:00 on August 12) O.P.+ 2,392 mm (Increase from initial level:3,118 mm, 172 mm increase since 7:00 on August 12) O.P.+ 4,251 mm (Water level from floor:455 mm, 1 mm increase since 7:00 on August 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 10:06 on August 5 to 9:38 on August 12)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:27 on August 12   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 8:21 AM on August 12, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 12:01 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 12:27 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.