

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 13)**

Water Level of the accumulated water (at 7:00 on August 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,109 mm (58 mm increase since 16:00 on August 12)	O.P.+ 3,091 mm (16 mm decrease since 16:00 on August 12)	—
	Water level of Turbine Building	O.P.+ 2,919 mm (10 mm increase since 16:00 on August 12)	O.P.+ 3,097 mm (51 mm increase since 16:00 on August 12)	O.P.+ 2,964 mm (39 mm decrease since 16:00 on August 12)	O.P.+ 2,950 mm (10 mm decrease since 16:00 on August 12)
	Water level of Reactor Building	O.P.+ 4,059 mm (23 mm decrease since 16:00 on August 12)	O.P.+ 3,150 mm (43 mm increase since 16:00 on August 12)	O.P.+ 3,021 mm (42 mm decrease since 16:00 on August 12)	O.P.+ 2,953 mm (6 mm decrease since 16:00 on August 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,363 mm (Increase from initial level:4,580 mm, 5 mm increase since 16:00 on August 12) O.P.+ 2,414 mm (Increase from initial level:3,140 mm, 22 mm increase since 16:00 on August 12) O.P.+ 4,252 mm (Water level from floor:456 mm, 1 mm increase since 16:00 on August 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:27 on August 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.