

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 13)**

Water Level of the accumulated water (at 16:00 on August 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,142 mm (33 mm increase since 7:00 on August 13)	O.P.+ 3,079 mm (12 mm decrease since 7:00 on August 13)	—
	Water level of Turbine Building	O.P.+ 2,926 mm (7 mm increase since 7:00 on August 13)	O.P.+ 3,124 mm (27 mm increase since 7:00 on August 13)	O.P.+ 2,944 mm (20 mm decrease since 7:00 on August 13)	O.P.+ 2,941 mm (9 mm decrease since 7:00 on August 13)
	Water level of Reactor Building	O.P.+ 4,052 mm (7 mm decrease since 7:00 on August 13)	O.P.+ 3,178 mm (28 mm increase since 7:00 on August 13)	O.P.+ 2,997 mm (24 mm decrease since 7:00 on August 13)	O.P.+ 2,946 mm (7 mm decrease since 7:00 on August 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,367 mm (Increase from initial level:4,584 mm, 4 mm increase since 7:00 on August 13) O.P.+ 2,430 mm (Increase from initial level:3,156 mm, 16 mm increase since 7:00 on August 13) O.P.+ 4,252 mm (Water level from floor:456 mm, No change since 7:00 on August 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:27 on August 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.