

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 14)**

Water Level of the accumulated water (at 7:00 on August 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,190 mm (48 mm increase since 16:00 on August 13)	O.P.+ 3,060 mm (19 mm decrease since 16:00 on August 13)	—
	Water level of Turbine Building	O.P.+ 2,935 mm (9 mm increase since 16:00 on August 13)	O.P.+ 3,165 mm (41 mm increase since 16:00 on August 13)	O.P.+ 2,915 mm (29 mm decrease since 16:00 on August 13)	O.P.+ 2,924 mm (17 mm decrease since 16:00 on August 13)
	Water level of Reactor Building	O.P.+ 4,040 mm (12 mm decrease since 16:00 on August 13)	O.P.+ 3,219 mm (41 mm increase since 16:00 on August 13)	O.P.+ 2,965 mm (32 mm decrease since 16:00 on August 13)	O.P.+ 2,935 mm (11 mm decrease since 16:00 on August 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,371 mm (Increase from initial level:4,588 mm, 4 mm increase since 16:00 on August 13) O.P.+ 2,454 mm (Increase from initial level:3,180 mm, 24 mm increase since 16:00 on August 13) O.P.+ 4,252 mm (Water level from floor:456 mm, No change since 16:00 on August 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:27 on August 12   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.