

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 14)**

Water Level of the accumulated water (at 16:00 on August 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,217 mm (27 mm increase since 7:00 on August 14)	O.P.+ 3,050 mm (10 mm decrease since 7:00 on August 14)	—
	Water level of Turbine Building	O.P.+ 2,942 mm (7 mm increase since 7:00 on August 14)	O.P.+ 3,188 mm (23 mm increase since 7:00 on August 14)	O.P.+ 2,898 mm (17 mm decrease since 7:00 on August 14)	O.P.+ 2,913 mm (11 mm decrease since 7:00 on August 14)
	Water level of Reactor Building	O.P.+ 4,039 mm (1 mm decrease since 7:00 on August 14)	O.P.+ 3,243 mm (24 mm increase since 7:00 on August 14)	O.P.+ 2,947 mm (18 mm decrease since 7:00 on August 14)	O.P.+ 2,927 mm (8 mm decrease since 7:00 on August 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,374 mm (Increase from initial level:4,591 mm, 3 mm increase since 7:00 on August 14) O.P.+ 2,471 mm (Increase from initial level:3,197 mm, 17 mm increase since 7:00 on August 14) O.P.+ 4,253 mm (Water level from floor:457 mm, 1 mm increase since 7:00 on August 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:27 on August 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.