

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 15)

Water Level of the accumulated water (at 7:00 on August 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,259 mm (42 mm increase since 16:00 on August 14)	O.P.+ 3,029 mm (21 mm decrease since 16:00 on August 14)	—
	Water level of Turbine Building	O.P.+ 2,951 mm (9 mm increase since 16:00 on August 14)	O.P.+ 3,224 mm (36 mm increase since 16:00 on August 14)	O.P.+ 2,872 mm (26 mm decrease since 16:00 on August 14)	O.P.+ 2,896 mm (17 mm decrease since 16:00 on August 14)
	Water level of Reactor Building	O.P.+ 4,044 mm (5 mm increase since 16:00 on August 14)	O.P.+ 3,280 mm (37 mm increase since 16:00 on August 14)	O.P.+ 2,920 mm (27 mm decrease since 16:00 on August 14)	O.P.+ 2,914 mm (13 mm decrease since 16:00 on August 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,380 mm (Increase from initial level:4,597 mm, 6 mm increase since 16:00 on August 14) O.P.+ 2,491 mm (Increase from initial level:3,217 mm, 20 mm increase since 16:00 on August 14) * O.P.+ 4,253 mm (Water level from floor:457 mm, No change since 16:00 on August 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:27 on August 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.

* We have corrected errors in the report. (Corrected on August 16, 2013)