

# **Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 15)**

Water Level of the accumulated water (at 16:00 on August 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,285 mm (26 mm increase since 7:00 on August 15)	O.P.+ 3,017 mm (12 mm decrease since 7:00 on August 15)	—
	Water level of Turbine Building	O.P.+ 2,957 mm (6 mm increase since 7:00 on August 15)	O.P.+ 3,247 mm (23 mm increase since 7:00 on August 15)	O.P.+ 2,858 mm (14 mm decrease since 7:00 on August 15)	O.P.+ 2,885 mm (11 mm decrease since 7:00 on August 15)
	Water level of Reactor Building	O.P.+ 4,049 mm (5 mm increase since 7:00 on August 15)	O.P.+ 3,303 mm (23 mm increase since 7:00 on August 15)	O.P.+ 2,907 mm (13 mm decrease since 7:00 on August 15)	O.P.+ 2,905 mm (9 mm decrease since 7:00 on August 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,383 mm (Increase from initial level:4,600 mm, 3 mm increase since 7:00 on August 15) O.P.+ 2,505 mm (Increase from initial level:3,231 mm, 14 mm increase since 7:00 on August 15) * O.P.+ 4,253 mm (Water level from floor:457 mm, No change since 7:00 on August 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:27 on August 12   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.

\* We have corrected errors in the report. (Corrected on August 16, 2013)