

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 16)**

Water Level of the accumulated water (at 7:00 on August 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,326 mm (41 mm increase since 16:00 on August 15)	O.P.+ 2,996 mm (21 mm decrease since 16:00 on August 15)	—
	Water level of Turbine Building	O.P.+ 2,966 mm (9 mm increase since 16:00 on August 15)	O.P.+ 3,281 mm (34 mm increase since 16:00 on August 15)	O.P.+ 2,834 mm (24 mm decrease since 16:00 on August 15)	O.P.+ 2,864 mm (21 mm decrease since 16:00 on August 15)
	Water level of Reactor Building	O.P.+ 4,064 mm (15 mm increase since 16:00 on August 15)	O.P.+ 3,337 mm (34 mm increase since 16:00 on August 15)	O.P.+ 2,881 mm (26 mm decrease since 16:00 on August 15)	O.P.+ 2,890 mm (15 mm decrease since 16:00 on August 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,388 mm (Increase from initial level:4,605 mm, 5 mm increase since 16:00 on August 15) O.P.+ 2,524 mm (Increase from initial level:3,250 mm, 19 mm increase since 16:00 on August 15) O.P.+ 4,254 mm (Water level from floor:458 mm, 1 mm increase since 16:00 on August 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:27 on August 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.