

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 16)**

Water Level of the accumulated water (at 16:00 on August 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,358 mm (32 mm increase since 7:00 on August 16)	O.P.+ 2,981 mm (15 mm decrease since 7:00 on August 16)	—
	Water level of Turbine Building	O.P.+ 2,972 mm (6 mm increase since 7:00 on August 16)	O.P.+ 3,309 mm (28 mm increase since 7:00 on August 16)	O.P.+ 2,828 mm (6 mm decrease since 7:00 on August 16)	O.P.+ 2,852 mm (12 mm decrease since 7:00 on August 16)
	Water level of Reactor Building	O.P.+ 4,078 mm (14 mm increase since 7:00 on August 16)	O.P.+ 3,363 mm (26 mm increase since 7:00 on August 16)	O.P.+ 2,871 mm (10 mm decrease since 7:00 on August 16)	O.P.+ 2,880 mm (10 mm decrease since 7:00 on August 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,391 mm (Increase from initial level:4,608 mm, 3 mm increase since 7:00 on August 16) O.P.+ 2,511 mm (Increase from initial level:3,237 mm, 13 mm decrease since 7:00 on August 16) O.P.+ 4,254 mm (Water level from floor:458 mm, No change since 7:00 on August 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:31 on August 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:27 on August 12   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.