

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 19)**

| | | | | | |
|---|--|--|--|--|---|
| Water Level of the accumulated water (at 16:00 on August 19) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 3,257 mm (23 mm decrease since 7:00 on August 19) | O.P.+ 2,969 mm (14 mm increase since 7:00 on August 19) | — |
| | Water level of Turbine Building | O.P.+ 3,014 mm (6 mm increase since 7:00 on August 19) | O.P.+ 3,220 mm (19 mm decrease since 7:00 on August 19) | O.P.+ 2,877 mm (17 mm increase since 7:00 on August 19) | O.P.+ 2,806 mm (3 mm increase since 7:00 on August 19) |
| | Water level of Reactor Building | O.P.+ 4,116 mm (2 mm decrease since 7:00 on August 19) | O.P.+ 3,301 mm (18 mm decrease since 7:00 on August 19) | O.P.+ 2,916 mm (17 mm increase since 7:00 on August 19) | O.P.+ 2,821 mm (2 mm decrease since 7:00 on August 19) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 3,417 mm (Increase from initial level:4,634 mm, 4 mm increase since 7:00 on August 19) O.P.+ 3,003 mm (Increase from initial level:3,729 mm, 64 mm decrease since 7:00 on August 19) O.P.+ 4,257 mm (Water level from floor:461 mm, No change since 7:00 on August 19) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 11:25 on August 18) | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2) | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:27 on August 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | | | | | |

※ For quick publication of the data of water level, values are provided as reference values.