

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 20)**

Water Level of the accumulated water (at 7:00 on August 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,227 mm (30 mm decrease since 16:00 on August 19)	O.P.+ 2,989 mm (20 mm increase since 16:00 on August 19)	—
	Water level of Turbine Building	O.P.+ 3,022 mm (8 mm increase since 16:00 on August 19)	O.P.+ 3,195 mm (25 mm decrease since 16:00 on August 19)	O.P.+ 2,897 mm (20 mm increase since 16:00 on August 19)	O.P.+ 2,821 mm (15 mm increase since 16:00 on August 19)
	Water level of Reactor Building	O.P.+ 4,111 mm (5 mm decrease since 16:00 on August 19)	O.P.+ 3,275 mm (26 mm decrease since 16:00 on August 19)	O.P.+ 2,956 mm (40 mm increase since 16:00 on August 19)	O.P.+ 2,824 mm (3 mm increase since 16:00 on August 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,422 mm (Increase from initial level:4,639 mm, 5 mm increase since 16:00 on August 19) O.P.+ 2,906 mm (Increase from initial level:3,632 mm, 97 mm decrease since 16:00 on August 19) O.P.+ 4,257 mm (Water level from floor:461 mm, No change since 16:00 on August 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 11:25 on August 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:31 on August 20 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*At 8:31 on August 20, we temporarily stopped the Second Cesium Adsorption Apparatus (SARRY) to wash the filters.				

※ For quick publication of the data of water level, values are provided as reference values.