

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 21)**

Water Level of the accumulated water (at 7:00 on August 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,180 mm (31 mm decrease since 16:00 on August 20)	O.P.+ 3,015 mm (15 mm increase since 16:00 on August 20)	—
	Water level of Turbine Building	O.P.+ 3,026 mm (1 mm decrease since 16:00 on August 20)	O.P.+ 3,156 mm (26 mm decrease since 16:00 on August 20)	O.P.+ 2,927 mm (17 mm increase since 16:00 on August 20)	O.P.+ 2,843 mm (14 mm increase since 16:00 on August 20)
	Water level of Reactor Building	O.P.+ 4,098 mm (6 mm decrease since 16:00 on August 20)	O.P.+ 3,236 mm (26 mm decrease since 16:00 on August 20)	O.P.+ 2,974 mm (No change since 16:00 on August 20)	O.P.+ 2,842 mm (12 mm increase since 16:00 on August 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,434 mm (Increase from initial level:4,651 mm, 4 mm decrease since 16:00 on August 20) O.P.+ 2,820 mm (Increase from initial level:3,546 mm, 196 mm decrease since 16:00 on August 20) O.P.+ 4,258 mm (Water level from floor:462 mm, No change since 16:00 on August 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 11:25 on August 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:12 on August 20 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.