

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 22)**

Water Level of the accumulated water (at 7:00 on August 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,138 mm (28 mm decrease since 16:00 on August 21)	O.P.+ 3,040 mm (17 mm increase since 16:00 on August 21)	—
	Water level of Turbine Building	O.P.+ 3,048 mm (7 mm increase since 16:00 on August 21)	O.P.+ 3,120 mm (24 mm decrease since 16:00 on August 21)	O.P.+ 2,955 mm (18 mm increase since 16:00 on August 21)	O.P.+ 2,865 mm (14 mm increase since 16:00 on August 21)
	Water level of Reactor Building	O.P.+ 4,082 mm (11 mm decrease since 16:00 on August 21)	O.P.+ 3,198 mm (25 mm decrease since 16:00 on August 21)	O.P.+ 3,003 mm (18 mm increase since 16:00 on August 21)	O.P.+ 2,863 mm (13 mm increase since 16:00 on August 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,443 mm (Increase from initial level:4,660 mm, 6 mm increase since 16:00 on August 21) O.P.+ 2,576 mm (Increase from initial level:3,302 mm, 152 mm decrease since 16:00 on August 21) O.P.+ 4,258 mm (Water level from floor:462 mm, No change since 16:00 on August 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 11:25 on August 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:12 on August 20 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.