

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 23)**

Water Level of the accumulated water (at 7:00 on August 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,116 mm (14 mm decrease since 16:00 on August 22)	O.P.+ 3,061 mm (18 mm increase since 16:00 on August 22)	—
	Water level of Turbine Building	O.P.+ 3,058 mm (7 mm increase since 16:00 on August 22)	O.P.+ 3,093 mm (19 mm decrease since 16:00 on August 22)	O.P.+ 2,980 mm (17 mm increase since 16:00 on August 22)	O.P.+ 2,887 mm (13 mm increase since 16:00 on August 22)
	Water level of Reactor Building	O.P.+ 4,058 mm (15 mm decrease since 16:00 on August 22)	O.P.+ 3,173 mm (14 mm decrease since 16:00 on August 22)	O.P.+ 3,034 mm (19 mm increase since 16:00 on August 22)	O.P.+ 2,885 mm (13 mm increase since 16:00 on August 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,451 mm (Increase from initial level:4,668 mm, 6 mm increase since 16:00 on August 22) O.P.+ 2,352 mm (Increase from initial level:3,078 mm, 142 mm decrease since 16:00 on August 22) O.P.+ 4,260 mm (Water level from floor:464 mm, No change since 16:00 on August 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 11:25 on August 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:12 on August 20 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.