

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 26)**

Water Level of the accumulated water (at 7:00 on August 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,239 mm (55 mm increase since 16:00 on August 25)	O.P.+ 3,021 mm (23 mm decrease since 16:00 on August 25)	—
	Water level of Turbine Building	O.P.+ 2,882 mm (8 mm decrease since 16:00 on August 25)	O.P.+ 3,204 mm (43 mm increase since 16:00 on August 25)	O.P.+ 2,883 mm (32 mm decrease since 16:00 on August 25)	O.P.+ 2,890 mm (17 mm decrease since 16:00 on August 25)
	Water level of Reactor Building	O.P.+ 4,032 mm (7 mm increase since 16:00 on August 25)	O.P.+ 3,256 mm (43 mm increase since 16:00 on August 25)	O.P.+ 2,938 mm (37 mm decrease since 16:00 on August 25)	O.P.+ 2,900 mm (10 mm decrease since 16:00 on August 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,491 mm (Increase from initial level:4,708 mm, 4 mm increase since 16:00 on August 25) O.P.+ 1,976 mm (Increase from initial level:2,702 mm, 36 mm decrease since 16:00 on August 25) O.P.+ 4,262 mm (Water level from floor:466 mm, No change since 16:00 on August 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:38 on August 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:12 on August 20 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	– Since 1:55 PM on August 24, water pumped up from the well point (pumping facility using a vacuum pump) installed east of Unit 2 Turbine Building has been transferred to Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.