

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 28)**

Water Level of the accumulated water (at 7:00 on August 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,271 mm (40 mm decrease since 16:00 on August 27)	O.P.+ 2,990 mm (6 mm increase since 16:00 on August 27)	—
	Water level of Turbine Building	O.P.+ 2,695 mm (4 mm increase since 16:00 on August 27)	O.P.+ 3,237 mm (36 mm decrease since 16:00 on August 27)	O.P.+ 2,888 mm (35 mm increase since 16:00 on August 27)	O.P.+ 2,841 mm (10 mm decrease since 16:00 on August 27)
	Water level of Reactor Building	O.P.+ 4,080 mm (13 mm increase since 16:00 on August 27)	O.P.+ 3,317 mm (29 mm decrease since 16:00 on August 27)	O.P.+ 2,934 mm (35 mm increase since 16:00 on August 27)	O.P.+ 2,860 mm (13 mm decrease since 16:00 on August 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,507 mm (Increase from initial level:4,724 mm, 4 mm increase since 16:00 on August 27) O.P.+ 2,210 mm (Increase from initial level:2,936 mm, 15 mm decrease since 16:00 on August 27) O.P.+ 4,263 mm (Water level from floor:467 mm, No change since 16:00 on August 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:18 on August 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:38 on August 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:33 on August 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- We are transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building since 13:55 on August 24.				

※ For quick publication of the data of water level, values are provided as reference values.