

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 29)**

Water Level of the accumulated water (at 7:00 on August 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,214 mm (36 mm decrease since 16:00 on August 28)	O.P.+ 3,006 mm (10 mm increase since 16:00 on August 28)	—
	Water level of Turbine Building	O.P.+ 2,703 mm (4 mm increase since 16:00 on August 28)	O.P.+ 3,184 mm (35 mm decrease since 16:00 on August 28)	O.P.+ 2,907 mm (9 mm increase since 16:00 on August 28)	O.P.+ 2,849 mm (7 mm increase since 16:00 on August 28)
	Water level of Reactor Building	O.P.+ 4,076 mm (5 mm decrease since 16:00 on August 28)	O.P.+ 3,268 mm (31 mm decrease since 16:00 on August 28)	O.P.+ 2,958 mm (11 mm increase since 16:00 on August 28)	O.P.+ 2,854 mm (2 mm decrease since 16:00 on August 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,518 mm (Increase from initial level:4,735 mm, 5 mm increase since 16:00 on August 28) O.P.+ 2,188 mm (Increase from initial level:2,914 mm, 14 mm decrease since 16:00 on August 28) O.P.+ 4,263 mm (Water level from floor:467 mm, No change since 16:00 on August 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:18 on August 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:38 on August 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:33 on August 27   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.