

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 29)**

Water Level of the accumulated water (at 16:00 on August 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,191 mm (23 mm decrease since 7:00 on August 29)	O.P.+ 3,011 mm (5 mm increase since 7:00 on August 29)	—
	Water level of Turbine Building	O.P.+ 2,705 mm (2 mm increase since 7:00 on August 29)	O.P.+ 3,166 mm (18 mm decrease since 7:00 on August 29)	O.P.+ 2,912 mm (5 mm increase since 7:00 on August 29)	O.P.+ 2,857 mm (8 mm increase since 7:00 on August 29)
	Water level of Reactor Building	O.P.+ 4,071 mm (5 mm decrease since 7:00 on August 29)	O.P.+ 3,251 mm (17 mm decrease since 7:00 on August 29)	O.P.+ 2,964 mm (6 mm increase since 7:00 on August 29)	O.P.+ 2,856 mm (2 mm increase since 7:00 on August 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,522 mm (Increase from initial level:4,739 mm, 4 mm increase since 7:00 on August 29) O.P.+ 2,181 mm (Increase from initial level:2,907 mm, 7 mm decrease since 7:00 on August 29) O.P.+ 4,264 mm (Water level from floor:468 mm, 1 mm increase since 7:00 on August 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:18 on August 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:38 on August 24)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on August 29 to 15:00 on August 29)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:33 on August 27   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.