

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 30)**

Water Level of the accumulated water (at 16:00 on August 30)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,139 mm (18 mm decrease since 7:00 on August 30)	O.P.+ 3,025 mm (4 mm increase since 7:00 on August 30)	—
	Water level of Turbine Building	O.P.+ 2,713 mm (3 mm increase since 7:00 on August 30)	O.P.+ 3,122 mm (15 mm decrease since 7:00 on August 30)	O.P.+ 2,929 mm (6 mm increase since 7:00 on August 30)	O.P.+ 2,874 mm (10 mm increase since 7:00 on August 30)
	Water level of Reactor Building	O.P.+ 4,054 mm (7 mm decrease since 7:00 on August 30)	O.P.+ 3,203 mm (18 mm decrease since 7:00 on August 30)	O.P.+ 2,980 mm (5 mm increase since 7:00 on August 30)	O.P.+ 2,871 mm (8 mm increase since 7:00 on August 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,530 mm (Increase from initial level:4,747 mm, 3 mm increase since 7:00 on August 30) O.P.+ 2,164 mm (Increase from initial level:2,890 mm, 6 mm decrease since 7:00 on August 30) O.P.+ 4,264 mm (Water level from floor:468 mm, No change since 7:00 on August 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:18 on August 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:38 on August 24)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on August 30 to 15:00 on August 30)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:33 on August 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.