

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 2)**

Water Level of the accumulated water (at 7:00 on September 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,020 mm (31 mm decrease since 16:00 on September 1)	O.P.+ 3,057 mm (5 mm increase since 16:00 on September 1)	—
	Water level of Turbine Building	O.P.+ 2,729 mm (3 mm increase since 16:00 on September 1)	O.P.+ 3,019 mm (29 mm decrease since 16:00 on September 1)	O.P.+ 2,963 mm (7 mm increase since 16:00 on September 1)	O.P.+ 2,900 mm (7 mm increase since 16:00 on September 1)
	Water level of Reactor Building	O.P.+ 3,975 mm (22 mm decrease since 16:00 on September 1)	O.P.+ 3,096 mm (31 mm decrease since 16:00 on September 1)	O.P.+ 3,019 mm (9 mm increase since 16:00 on September 1)	O.P.+ 2,897 mm (7 mm increase since 16:00 on September 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,550 mm (Increase from initial level:4,767 mm, 5 mm increase since 16:00 on September 1) O.P.+ 2,135 mm (Increase from initial level:2,861 mm, 3 mm decrease since 16:00 on September 1) O.P.+ 4,265 mm (Water level from floor:469 mm, 1 mm increase since 16:00 on September 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:18 on August 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:38 on August 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:33 on August 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 3:55 PM on August 31, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.