

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 4)**

Water Level of the accumulated water (at 7:00 on September 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,947 mm (14 mm decrease since 16:00 on September 3)	O.P.+ 3,043 mm (18 mm decrease since 16:00 on September 3)	—
	Water level of Turbine Building	O.P.+ 2,739 mm (3 mm increase since 16:00 on September 3)	O.P.+ 2,960 mm (12 mm decrease since 16:00 on September 3)	O.P.+ 2,912 mm (42 mm decrease since 16:00 on September 3)	O.P.+ 2,902 mm (11 mm decrease since 16:00 on September 3)
	Water level of Reactor Building	O.P.+ 3,907 mm (19 mm decrease since 16:00 on September 3)	O.P.+ 3,033 mm (8 mm decrease since 16:00 on September 3)	O.P.+ 2,972 mm (42 mm decrease since 16:00 on September 3)	O.P.+ 2,904 mm (7 mm decrease since 16:00 on September 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,567 mm (Increase from initial level:4,784 mm, 5 mm increase since 16:00 on September 3) O.P.+ 2,496 mm (Increase from initial level:3,222 mm, 279 mm increase since 16:00 on September 3) O.P.+ 4,267 mm (Water level from floor:471 mm, 1 mm increase since 16:00 on September 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:19 on September 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:38 on August 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:24 on September 4 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:24 AM on September 4, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. - Since 2:56 PM on September 3, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.