

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 5)**

Water Level of the accumulated water (at 7:00 on September 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,028 mm (52 mm increase since 16:00 on September 4)	O.P.+ 3,015 mm (20 mm decrease since 16:00 on September 4)	—
	Water level of Turbine Building	O.P.+ 2,745 mm (3 mm increase since 16:00 on September 4)	O.P.+ 3,030 mm (46 mm increase since 16:00 on September 4)	O.P.+ 2,863 mm (30 mm decrease since 16:00 on September 4)	O.P.+ 2,874 mm (18 mm decrease since 16:00 on September 4)
	Water level of Reactor Building	O.P.+ 3,873 mm (16 mm decrease since 16:00 on September 4)	O.P.+ 3,079 mm (46 mm increase since 16:00 on September 4)	O.P.+ 2,912 mm (34 mm decrease since 16:00 on September 4)	O.P.+ 2,893 mm (10 mm decrease since 16:00 on September 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,576 mm (Increase from initial level:4,793 mm, 5 mm increase since 16:00 on September 4) O.P.+ 2,738 mm (Increase from initial level:3,464 mm, 1 mm increase since 16:00 on September 4) O.P.+ 4,267 mm (Water level from floor:471 mm, No change since 16:00 on September 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:38 on August 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:20 on September 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 2:21 PM on September 4, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.