

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on September 5)**

| | | | | | |
|---|--|--|---|---|--|
| Water Level of the accumulated water (at 16:00 on September 5) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 3,062 mm (34 mm increase since 7:00 on September 5) | O.P.+ 3,002 mm (13 mm decrease since 7:00 on September 5) | — |
| | Water level of Turbine Building | O.P.+ 2,747 mm (2 mm increase since 7:00 on September 5) | O.P.+ 3,059 mm (29 mm increase since 7:00 on September 5) | O.P.+ 2,846 mm (17 mm decrease since 7:00 on September 5) | O.P.+ 2,864 mm (10 mm decrease since 7:00 on September 5) |
| | Water level of Reactor Building | O.P.+ 3,866 mm (7 mm decrease since 7:00 on September 5) | O.P.+ 3,105 mm (26 mm increase since 7:00 on September 5) | O.P.+ 2,895 mm (17 mm decrease since 7:00 on September 5) | O.P.+ 2,884 mm (9 mm decrease since 7:00 on September 5) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 3,580 mm (Increase from initial level:4,797 mm, 4 mm increase since 7:00 on September 5) O.P.+ 2,747 mm (Increase from initial level:3,473 mm, 9 mm increase since 7:00 on September 5) O.P.+ 4,266 mm (Water level from floor:470 mm, 1 mm decrease since 7:00 on September 5) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | — | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:38 on August 24) | — |
| | | Unit 5 and 6 | | | |
| | | Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on September 5 to 15:00 on September 5) | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:20 on September 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | * Water transfer was done from the well point of Unit 2 turbine building to Unit 2 turbine building from 14:21 September 4 to 13:01 on September 5. We restarted it at 14:07. * Water transfer was done from the vertical duct B to Unit 2 turbine building from 13:14 to 13:47 on September 5. | | | | |

※ For quick publication of the data of water level, values are provided as reference values.