

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on September 9)**

Water Level of the accumulated water (at 16:00 on September 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,159 mm (28 mm decrease since 7:00 on September 9)	O.P.+ 2,932 mm (12 mm increase since 7:00 on September 9)	—
	Water level of Turbine Building	O.P.+ 2,761 mm (1 mm increase since 7:00 on September 9)	O.P.+ 3,140 mm (24 mm decrease since 7:00 on September 9)	O.P.+ 2,829 mm (14 mm increase since 7:00 on September 9)	O.P.+ 2,771 mm (6 mm increase since 7:00 on September 9)
	Water level of Reactor Building	O.P.+ 3,922 mm (2 mm increase since 7:00 on September 9)	O.P.+ 3,209 mm (21 mm decrease since 7:00 on September 9)	O.P.+ 2,876 mm (16 mm increase since 7:00 on September 9)	O.P.+ 2,788 mm (4 mm decrease since 7:00 on September 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,614 mm (Increase from initial level:4,831 mm, 7 mm increase since 7:00 on September 9) O.P.+ 2,693 mm (Increase from initial level:3,419 mm, 45 mm decrease since 7:00 on September 9) O.P.+ 4,268 mm (Water level from floor:472 mm, 1 mm increase since 7:00 on September 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:09 on September 8)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:26 on September 8)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on September 9 to 15:00 on September 9)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:20 on September 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*From 13:33 on September 7, we are transferring pumped up water from the well point at the east side of Unit 2 Turbine Building to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.