

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 10)**

Water Level of the accumulated water (at 7:00 on September 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,118 mm (41 mm decrease since 16:00 on September 9)	O.P.+ 2,948 mm (16 mm increase since 16:00 on September 9)	—
	Water level of Turbine Building	O.P.+ 2,764 mm (3 mm increase since 16:00 on September 9)	O.P.+ 3,104 mm (36 mm decrease since 16:00 on September 9)	O.P.+ 2,850 mm (21 mm increase since 16:00 on September 9)	O.P.+ 2,782 mm (11 mm increase since 16:00 on September 9)
	Water level of Reactor Building	O.P.+ 3,919 mm (3 mm decrease since 16:00 on September 9)	O.P.+ 3,171 mm (38 mm decrease since 16:00 on September 9)	O.P.+ 2,900 mm (24 mm increase since 16:00 on September 9)	O.P.+ 2,787 mm (1 mm decrease since 16:00 on September 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,619 mm (Increase from initial level:4,836 mm, 5 mm increase since 16:00 on September 9) O.P.+ 2,623 mm (Increase from initial level:3,349 mm, 70 mm decrease since 16:00 on September 9) O.P.+ 4,267 mm (Water level from floor:471 mm, 1 mm decrease since 16:00 on September 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:09 on September 8)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:26 on September 8)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:20 on September 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.