

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 12)**

Water Level of the accumulated water (at 7:00 on September 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,981 mm (41 mm decrease since 16:00 on September 11)	O.P.+ 2,997 mm (13 mm increase since 16:00 on September 11)	—
	Water level of Turbine Building	O.P.+ 2,770 mm (2 mm increase since 16:00 on September 11)	O.P.+ 2,990 mm (34 mm decrease since 16:00 on September 11)	O.P.+ 2,904 mm (15 mm increase since 16:00 on September 11)	O.P.+ 2,824 mm (12 mm increase since 16:00 on September 11)
	Water level of Reactor Building	O.P.+ 3,884 mm (13 mm decrease since 16:00 on September 11)	O.P.+ 3,063 mm (34 mm decrease since 16:00 on September 11)	O.P.+ 2,957 mm (16 mm increase since 16:00 on September 11)	O.P.+ 2,824 mm (13 mm increase since 16:00 on September 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,636 mm (Increase from initial level:4,853 mm, 5 mm increase since 16:00 on September 11) O.P.+ 2,413 mm (Increase from initial level:3,139 mm, 66 mm decrease since 16:00 on September 11) O.P.+ 4,268 mm (Water level from floor:472 mm, 1 mm increase since 16:00 on September 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:09 on September 8)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:26 on September 8)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:24 on September 12 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:24 AM on September 12, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. - Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.