

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 13)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on September 13)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,917 mm (39 mm decrease since 16:00 on September 12)	O.P.+ 3,021 mm (15 mm increase since 16:00 on September 12)	—
	Water level of Turbine Building	O.P.+ 2,774 mm (3 mm increase since 16:00 on September 12)	O.P.+ 2,936 mm (33 mm decrease since 16:00 on September 12)	O.P.+ 2,930 mm (17 mm increase since 16:00 on September 12)	O.P.+ 2,846 mm (13 mm increase since 16:00 on September 12)
	Water level of Reactor Building	O.P.+ 3,858 mm (17 mm decrease since 16:00 on September 12)	O.P.+ 3,014 mm (30 mm decrease since 16:00 on September 12)	O.P.+ 2,983 mm (16 mm increase since 16:00 on September 12)	O.P.+ 2,844 mm (12 mm increase since 16:00 on September 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,646 mm (Increase from initial level:4,863 mm, 5 mm increase since 16:00 on September 12) O.P.+ 2,406 mm (Increase from initial level:3,132 mm, 84 mm decrease since 16:00 on September 12) O.P.+ 4,267 mm (Water level from floor:471 mm, 1 mm decrease since 16:00 on September 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:09 on September 8)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:26 on September 8)	—
		Unit 5 and 6 —			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:00 on September 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.