

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 18)**

Water Level of the accumulated water (at 7:00 on September 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,855 mm (53 mm increase since 16:00 on September 17)	O.P.+ 3,109 mm (20 mm decrease since 16:00 on September 17)	—
	Water level of Turbine Building	O.P.+ 2,842 mm (11 mm increase since 16:00 on September 17)	O.P.+ 2,886 mm (48 mm increase since 16:00 on September 17)	O.P.+ 2,985 mm (47 mm decrease since 16:00 on September 17)	O.P.+ 2,961 mm (3 mm decrease since 16:00 on September 17)
	Water level of Reactor Building	O.P.+ 4,060 mm (4 mm increase since 16:00 on September 17)	O.P.+ 2,933 mm (42 mm increase since 16:00 on September 17)	O.P.+ 3,056 mm (52 mm decrease since 16:00 on September 17)	O.P.+ 2,958 mm (1 mm increase since 16:00 on September 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,687 mm (Increase from initial level:4,904 mm, 4 mm increase since 16:00 on September 17) O.P.+ 1,931 mm (Increase from initial level:2,657 mm, 31 mm increase since 16:00 on September 17) O.P.+ 4,270 mm (Water level from floor:474 mm, No change since 16:00 on September 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:37 on September 17)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:00 on September 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.