

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 19)**

Water Level of the accumulated water (at 7:00 on September 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,930 mm (45 mm increase since 16:00 on September 18)	O.P.+ 3,081 mm (19 mm decrease since 16:00 on September 18)	—
	Water level of Turbine Building	O.P.+ 2,857 mm (9 mm increase since 16:00 on September 18)	O.P.+ 2,950 mm (40 mm increase since 16:00 on September 18)	O.P.+ 2,932 mm (31 mm decrease since 16:00 on September 18)	O.P.+ 2,936 mm (16 mm decrease since 16:00 on September 18)
	Water level of Reactor Building	O.P.+ 4,068 mm (5 mm increase since 16:00 on September 18)	O.P.+ 3,004 mm (39 mm increase since 16:00 on September 18)	O.P.+ 2,999 mm (33 mm decrease since 16:00 on September 18)	O.P.+ 2,939 mm (13 mm decrease since 16:00 on September 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,700 mm (Increase from initial level:4,917 mm, 4 mm increase since 16:00 on September 18) O.P.+ 1,983 mm (Increase from initial level:2,709 mm, 28 mm increase since 16:00 on September 18) O.P.+ 4,271 mm (Water level from floor:475 mm, 1 mm increase since 16:00 on September 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:37 on September 17)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:00 on September 12   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.