

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on September 20)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on September 20)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,031 mm (29 mm increase since 7:00 on September 20)	O.P.+ 3,042 mm (14 mm decrease since 7:00 on September 20)	—
	Water level of Turbine Building	O.P.+ 2,878 mm (6 mm increase since 7:00 on September 20)	O.P.+ 3,040 mm (27 mm increase since 7:00 on September 20)	O.P.+ 2,878 mm (13 mm decrease since 7:00 on September 20)	O.P.+ 2,893 mm (13 mm decrease since 7:00 on September 20)
	Water level of Reactor Building	O.P.+ 4,061 mm (9 mm decrease since 7:00 on September 20)	O.P.+ 3,087 mm (26 mm increase since 7:00 on September 20)	O.P.+ 2,934 mm (16 mm decrease since 7:00 on September 20)	O.P.+ 2,910 mm (7 mm decrease since 7:00 on September 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,711 mm (Increase from initial level:4,928 mm, 3 mm increase since 7:00 on September 20) O.P.+ 2,184 mm (Increase from initial level:2,910 mm, 15 mm increase since 7:00 on September 20) O.P.+ 4,272 mm (Water level from floor:476 mm, 1 mm increase since 7:00 on September 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:37 on September 17)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:00 on September 19 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.