

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 24)**

| | | | | | |
|---|---|---|--|--|--|
| Water Level of the accumulated water (at 7:00 on September 24) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 3,297 mm (43 mm increase since 16:00 on September 23) | O.P.+ 2,924 mm (20 mm decrease since 16:00 on September 23) | — |
| | Water level of Turbine Building | O.P.+ 2,927 mm (8 mm increase since 16:00 on September 23) | O.P.+ 3,268 mm (36 mm increase since 16:00 on September 23) | O.P.+ 2,747 mm (23 mm decrease since 16:00 on September 23) | O.P.+ 2,777 mm (21 mm decrease since 16:00 on September 23) |
| | Water level of Reactor Building | O.P.+ 4,047 mm (7 mm increase since 16:00 on September 23) | O.P.+ 3,318 mm (35 mm increase since 16:00 on September 23) | O.P.+ 2,796 mm (24 mm decrease since 16:00 on September 23) | O.P.+ 2,813 mm (19 mm decrease since 16:00 on September 23) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 3,734 mm (Increase from initial level:4,951 mm, 4 mm increase since 16:00 on September 23) O.P.+ 2,438 mm (Increase from initial level:3,164 mm, 49 mm increase since 16:00 on September 23) O.P.+ 4,276 mm (Water level from floor:480 mm, 1 mm increase since 16:00 on September 23) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | — | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:37 on September 17) | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:00 on September 19 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | - Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building. | | | | |

※ For quick publication of the data of water level, values are provided as reference values.