

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on September 25)**

Water Level of the accumulated water (at 16:00 on September 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,224 mm (22 mm decrease since 7:00 on September 25)	O.P.+ 2,939 mm (11 mm increase since 7:00 on September 25)	—
	Water level of Turbine Building	O.P.+ 2,944 mm (5 mm increase since 7:00 on September 25)	O.P.+ 3,204 mm (20 mm decrease since 7:00 on September 25)	O.P.+ 2,831 mm (13 mm increase since 7:00 on September 25)	O.P.+ 2,771 mm (7 mm increase since 7:00 on September 25)
	Water level of Reactor Building	O.P.+ 4,057 mm (1 mm decrease since 7:00 on September 25)	O.P.+ 3,279 mm (16 mm decrease since 7:00 on September 25)	O.P.+ 2,881 mm (16 mm increase since 7:00 on September 25)	O.P.+ 2,785 mm (4 mm decrease since 7:00 on September 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,741 mm (Increase from initial level:4,958 mm, 2 mm increase since 7:00 on September 25) O.P.+ 2,349 mm (Increase from initial level:3,075 mm, 26 mm decrease since 7:00 on September 25) O.P.+ 4,276 mm (Water level from floor:480 mm, No change since 7:00 on September 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:56 on September 24)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:22 on September 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:00 on September 19 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* Water transfer was done from the well point at the east side of Unit 2 turbine building to Unit 2 turbine building from 13:33 September 7.				

※ For quick publication of the data of water level, values are provided as reference values.